



SHIELD



Imported From **Na-De** Company

Conventional / Addressable Fire Alarm Detector



► **Smoke Detector**

- **Operation :distraction of light, (the tindal effect) microprocessor controlled**
- **Supply Voltage :15~30 VDC**
- **Terminals : for wires with cross section 0.8~2.5 mm²**
- **Degree of protection : IP 43**
- **Relative humidity : (93±3)% at 40°C**
- **Sensitivity : in accordance with EN54~7**
- **Isolater**



► **Heat Detector**

- **Operation : microprocessor controlled fixed temperature threshold dependable**
- **Supply voltage : 15~30VDC**
- **Terminals : for wires with cross section 0.8~2.5mm²**
- **Degree of protection : IP43**
- **Relative humidity : (93±3)%at40°C**
- **Sensitivity : in accordance with EN54~5**
- **Isolater**



► **Combine Detector**

- **Operation : distraction of light, microprocessor controlled**
- **fixed temperature threshold dependable**
- **Supply Voltage :15~30VDC**
- **Terminals :for wires with cross section0.8~2.5mm²**
- **Degree of protection :IP 43**
- **Relative humidity : (93±3)%at40°C**
- **Sensitivity : in accordance with EN54~7,EN54~5**
- **Isolater**



www.shieldfirefighting.com



Location : North Al Batinah governorate, Sohar FZ ,Oman

Contact US: 0096871714938